



TESTED MATERIAL: Sikkens Rubbol BL Rezisto Mat

CLIENT: Akzo Nobel Paints Belgium NV/SA
Everest Office Park
Leuvensesteenweg 248 B
1800 Vilvoorde
BELGIEN

TEST INSTITUTE: ilf Magdeburg GmbH / Materials testing

TEST REPORT: 250070-2

TEST RESULT:

We hereby confirm that the tested interior wall paint Sikkens Rubbol BL Rezisto Mat is resistant to the following surface disinfectants at the specified concentrations and exposure times.

Disinfectant	Concentration	Duration
Kohrsolin FF	3%	1 h / 3h
Terralin protect	0,5%	1h
puresept	2%	1 h / 3h
Buraton rapid	100%	5min / 10min
Incidin liquid	100%	5min / 10min
Bacillol AF	100%	5min / 10min

Magdeburg, 28.03.2025

Dipl.-Chem. Katrin Döring
Leiterin Materialprüfung

Dipl.-Phys. Torsten Doege
verantwortlicher Prüfer