

Attestation

BREEAM International

On 7 February 2018 for VOC emission and 31 January for VOC content, Eurofins Product Testing A/S received a sample of a paint with the product name:

Dulux Trade Quick Dry Undercoat White

supplied by

AkzoNobel Decorative Paints

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in Indoor Air Comfort GOLD version 6.0: EN 16516, EN 16402, ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 11890-2, respectively (See test report no. 392-2018-00057109_A_EN and 392-2020-00056616_XG_EN).

Evaluation of the emission and content test results according to the exemplary level emission criteria (table 18) and VOC content criteria (table 19) of: BREEAM Int.: Hea 02 Indoor air quality:

- Carcinogenic substances were not detectable after 28 days ($< 0.001 \text{ mg/m}^3$).
 - The sum of VOC ("TVOC") after 28 days was below the limit of 0.3 mg/m^3 .
 - The sum of SVOC after 28 day was below the limit of 0.1 mg/m^3 .
 - Formaldehyde after 28 days was below the limit of 0.01 mg/m^3 .
 - VOC content of less than 90 g/L as for the product type interior/exterior trim and cladding paints for wood and metal.
-

The tested product complies with the requirements of BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor air quality (version SD233 issue 2.0 of July 2017).

17 April 2020



Janne Rothmann Norup
Analytical Service Manager