

Attestation

BREEAM[®] UK and BREEAM[®] Int.

On 30 November 2017 and 24 February 2020, Eurofins Product Testing A/S received samples of primer with the product name:

Dulux Trade Quick Dry Wood Primer Undercoat

supplied by

AkzoNobel Decorative Paints

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the testing standards specified in Indoor Air Comfort GOLD version 6.0: EN 16516, EN 16402 ISO 16000-3, ISO 16000-6, ISO 16000-9, ISO 16000-11 and ISO 11890-2, respectively (See test report no. 392-2017-00440201_A_EN and 392-2020-00092106_XG_EN).

Evaluation of the emission and content test results according to the exemplary level emission criteria and VOC content criteria of BREEAM[®] Int. and BREEAM[®] UK:

- Carcinogenic substances were not detectable after 28 days ($< 0.001 \text{ mg/m}^3$).
- The sum of VOC ("TVOC") after 28 days was below the limit of 0.3 mg/m^3 .
- The sum of SVOC after 28 days was below the limit of 0.1 mg/m^3 .
- Formaldehyde after 28 days was below the limit of 0.01 mg/m^3 .
- VOC content of less than 10 g/L .

The tested product complies with the requirements of:

BREEAM[®] UK: New Construction 2018, Technical Manual: Hea 02 Indoor air quality (version SD5078 issue 3.0 of July 2019)
and

BREEAM[®] International: BREEAM International: New Construction 2016, Technical Manual: Hea 02 Indoor Air Quality (version SD233 issue 2.0 of July 2017).

2 November 2020



Janne Rothmann Norup
Analytical Service Manager



Rasmus Stengaard Christensen
Analytical Service Manager, MSc in Chemistry