

Confirmation

LEED v4.1

On 30 November 2017 for VOC emission and 24 February 2020 for VOC content, Eurofins Product Testing A/S received a sample of a primer with the product name:

Dulux Trade Quick Dry Wood Primer Undercoat

supplied by

Akzo Nobel Decorative Paints

The sample was supplied as being representative of the manufactured product, and it has been tested in accordance with the relevant ISO 16000, EN 16516, ISO 11890-2 testing standards (See test report no. 392-2017-00440201_A_EN and no. 392-2020-00092106_XG_EN).

The test results of the tested sample indicate that the product qualifies for LEED v4.1 BETA (July 2019) specifications on VOC emissions and VOC content by complying with:

VOC emissions specifications in LEED EQ credit "Low-emitting products":

- The requirements of Option 2 of LEED v4.1 BETA (July 2019) by not exceeding the LCI values mentioned in the German AgBB Testing and Evaluation Scheme (2018), showing an overall R-value below 1 and having a TVOC according to EN 16516 below 0.5 mg/m³ and a formaldehyde emission below 10 µg/m³ after 28 days.

VOC content specifications in LEED EQ credit "Low-emitting products":

- the requirements of the EU Decopaint Directive 2004/42/CE

20 May 2020



Janne Rothmann Norup
Analytical Service Manager

LEED® is the preeminent program for the design, construction, maintenance and operations of high-performance green buildings. USGBC® and the related logo are trademarks owned by the U.S. Green Building Council and are used with permission.